

100702

NON DISCRETIONAL
UNTIL SUPERSEDED

ORIGINATOR: R. BOEDDEKER

DATE: 2/8/89
REVISED: _____PRESSURE VESSEL DESIGN & INSPECTION SHEET

Name of Vessel: Extraction Columns

Contents: Shellside: Tubeside:

Type of Construction: FUSION WELDED, ASME CODE, STAMPED 1989

NON DISCRETION

Drawing No. : - P&G
- Fabricator Precision Stainless 43899D

Material Specifications:	P&G No.	Plant	Dept.	Eng. Div. No.
Shell Side: SA-240-304L		Sherman		10872-1
		Sherman		10872-2
		Sherman		10872-3
Tube, Jacket		Sherman		10872-4
or Coil Side:		Sherman		10872-5
		Sherman		10872-6

Field Tests & Inspections

Shell	Max. All. Press.	150 PSI	5 Yr.	Internal
	Max. All. Temp.	400 F	1 Yr.	External
Tubes.	Max. All. Press.			Yr. Internal
Jacket, Max. All. Temp.				Yr. External
or Coil				

NOTE: For all heat exchangers, the Pressure Vessel Group is to be notified in the event of a change from the original operating conditions.

COMMENTS:

REVISION DATE: _____ SIGNATURE: _____ P.V. NO. _____

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
 (Alternative Form for Single Chamber, Completely Shop-Fabricated Vessels Only)
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

EQ. NO. 22-C-18

 NON DISCRETIONARY
 CIVIL COURT ORDERED

1. Manufactured and certified by Precision Stainless, Inc., 501 N. Balcrest, Springfield, MO 65802
 (Name and address of manufacturer)
 2. Manufactured for Procter & Gamble, Cincinnati, OH
 (Name and address of purchaser)
 3. Location of installation The Folger Coffee Company, 400 West F. M. 1417, Sherman, TX 75090
 (Name and address)
 4. Type Vertical 8985-1 thru 8985-6 43899-D 2429 thru 2434 1989
 (Name of vessel, tank) (Unit's serial No.) (CRN) (Drawing No.) (Mater. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986 Edition
 (Year)

6. Addendum A-87
 (Addendum No.)

7. Shell: SA240 304L .25 0 2'-11-1/2" 38'-7-15/16"
 (Mat. Spec. No., Grade) (Nom. Thk. in.) (Cor. Allow. in.) (Diam. I.D. in. & in.) (Length overall in. & in.)
 8. Heads: Welded Single Butt Spot 85 Welded Double Butt Spot 4
 (Type, No., Grade) (R.T. (Spa) or Full) (H.T. (Spa) or Full) (H.T. Temp. °F) (Type (in)) (Dir. (Welded, Spot, or Full)) (R.T. (Spa) or Full) (No. of Corros.)
 9. Heads: (a) Mat. SA240 304L (b) Mat. SA240 304L
 (Spec. No., Grade) (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Profile (Convex or Concave)
(a)	Top	313	0	--	--	2:1	--	--	--	Concave
(b)	Bottom	250	0	--	--	--	26°	--	--	--

If removable, bolts used (describe other fastenings):

9. MAWP 150 400 psi at max. temp. 400 °F
 Min. design metal temp. -20 °F at 150 psi. Hydro. or pneu. test pressure 241 psi.

10. Nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain)	No.	Diam. or Size	Type	Mat.	Nom. Thk.	Reinforcement Mat.	How Attached	Location
See 11-4								

11. Supports: Skirt No Lugs 4 Lugs -- Other -- Attached Shell Weld
 (Yes or No) (No.) (No.) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: Customer to install gate valve between transition and both head and supply bolts.
 (Items of part, item number, title's name and identifying stamp)

Transition shell 250 mm thickness, 3 K. R., SA240 304L. Name plate per Code Case 2051.
Support rings 3/8 plate, SA240 304. Customer to install safety valves. Vessel hydro-
statically tested in horizontal position at 241 psi. See 11-4.

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1, "U" Certificate of Authorization No. 11658 expires April 6, 1992.
 Date 6-8-89 Co. name Precision Stainless, Inc. signed Donna D. Morgan
 (Manufacturer) (Inspector)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Precision Stainless, Inc. at Springfield, MO
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Texas and employed by Commercial Union Insurance Co.
 have inspected the component described in this Manufacturer's Data Report on April 14, 1989, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 6-8-89 signed Donna D. Morgan Commission NS 8293 2445
 (Inspector) (Inspector's No.) (Inspector's No.)

FORM R-2 REPORT OF ALTERATION
in accordance with provisions of the National Board Inspection Code

1. Work performed by Paul Mueller Company
(name of alteration organization) (Form R No.)
1600 W. Phelps, PO Box 828, Springfield, MO 65802
(address)
2. Owner FOLGERS COFFEE COMPANY
(name)
300 F.M. HWY 1417 WEST SHERMAN TX 75092
(address)
3. Location of installation SAME AS ABOVE
(name)
(address)
4. Unit identification *SEE REMARKS Name of original manufacturer *SEE REMARKS
(boiler, pressure vessel)
5. Identifying nos.: *SEE REMARKS *SEE REMARKS 235290-7 THRU -12 *SEE REMARKS
(mfg serial no.) (National Board No.) (jurisdiction no.) (other) (year built)
6. NBIC Edition/Addenda: 1998 A98 Original Construction Code: *SEE REMARKS
(incl. edition and addenda)
7. Description of work: PAUL MUELLER COMPANY TO REMOVE EXISTING STACEY LINE BLIND ON THE LOWER END OF SIX
(use supplemental sheet, Form R-4, if necessary)
CONES AND REPLACE EACH WITH A 12" TYPE A-304L S/20 MSS STUB END, 12" A-105 LAP JOINT FLANGE AND A 1"
SCH 40 304/304L VANSTONE NOZZLE ASSEMBLY. HYDROSTATICALLY TEST VESSEL AFTER REWORK AT 256 PSI.

Pressure test, if applied 256 psi

8. Replacement Parts. Attached are Manufacturer's Partial Data Reports or Form R-3's properly completed for the following items of this report:

(name of part, item number, data report type, mfr's. name and identifying stamp)

9. Remarks: CUSTOMER REQUESTS ALTERATIONS TO BE MADE UPON SIX CONE ASSEMBLIES, WHICH WERE RECEIVED BY PAUL MUELLER COMPANY, WITHOUT MARKINGS TRACEABLE TO THE ORIGINAL MANUFACTURER OR TO A NATIONAL BOARD NUMBER.

NATIONAL BOARD INSPECTION CODE

Form R-2 (back)

(Form R No.)

DESIGN CERTIFICATION

I, Russell D. Copeland, certify that to the best of my knowledge and belief the statements in this report are correct and that the Design Change described in this report conforms to the National Board Inspection Code.

National Board "R" Certificate of Authorization No. 2957 expires on OCT, 27 20 01
 Date 11/5/99, 19 99 Paul Mueller Company Signed Russell D. Copeland
(name of design organization) (authorized representative)

CERTIFICATE OF DESIGN CHANGE REVIEW

I, Frank Hantak, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the jurisdiction of Missouri and employed by Commercial Union Ins Co. of Boston Ma have

reviewed the design change as described in this report and state that to the best of my knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code.

By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection.

Date 11-5, 19 99 Signed Frank Hantak Commissions NB# 11474A
(inspector) (National Board (incl. endorsements), and jurisdiction, and no.)

CONSTRUCTION CERTIFICATION

I, Russell D. Copeland, certify that to the best of my knowledge and belief the statements in this report are correct and that all material, construction, and workmanship on this Alteration conforms to the National Board Inspection Code.

National Board "R" Certificate of Authorization No. 2957 expires on OCT, 27 20 01
 Date 11/5, 19 99 Paul Mueller Company Signed Russell D. Copeland
(name of Alteration organization) (authorized representative)

CERTIFICATE OF INSPECTION

I, Frank Hantak, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the jurisdiction of Missouri and employed by Commercial Union Ins Co of Boston Ma have

inspected the work described in this report on 11-5, 19 99 and state that to the best of my knowledge and belief this work complies with the applicable requirements of the National Board Inspection Code.

By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection.

Date 11-5, 19 99 Signed Frank Hantak Commissions NB# 11474A
(inspector) (National Board (incl. endorsements), and jurisdiction, and no.)

NON DISCRETIONARY
UNTIL SUPER SEDED

NATL B3.

SERIAL NO. 2434

CERTIFIED BY
PRECISION
STAINLESS INC.
SPRINGFIELD, MO

MAXIMUM WORKING PRESSURE

300 PSIG AT 400 °F

MIN. DESIGN METAL TEMP.

320 °F AT 150 PSI

MFG'S SERIAL NO. 8085

YEAR BUILT 1989

SHELL THICKNESS 25

HEAD THICKNESS 375 / 25

HEAD DISH RADIUS 36