






1. Need width to be UNDER 12'
2. Need shroud cover removed to make it 11'3 3/4"
3. Need Length to be 21'6"

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches. Weights are in pounds and include options and accessories.
- 2) Unless otherwise indicated, connections 3" and smaller are MPT. Connections 4" and larger are grooved to suit a mechanical coupling and beveled for welding.
- 3) Field piping should be fabricated at time of installation. Pre-fabrication of pipe work is not recommended.
- 4) Do not support piping from unit connections. All necessary piping supports to be supplied by others.
- 5) For weight loadings and support requirements, refer to the suggested unit support drawing.
- 6) The area above the fan discharge must be unobstructed.
- 7) Due to height limitations on truck shipments, some items shown may ship loose for field installation.



Model Number	Shipping Weight	Operating Weight	Heaviest Section
3473C-MM/X	11940	23770	11540

STEEL CASING PANELS

ORDER NO: U110074403-QTY 2

DATE: 12/15/2010



Baltimore Aircoil

3000C Unit Print
One Piece UnitsDRAWING NUMBER:
UP-U110074403AXREVB

B