

1. Manufactured and certified by TEXAS DIVISION - TRANTER, INC. OLD BURK RD., WICHITA FALLS, TEXAS

2. Manufactured for ROHM AND HAAS BAYPORT PHILADELPHIA, PA

3. Location of installation ROHM AND HAAS BAYPORT INC. LA PORTE, TEXAS

4. Type VERTICAL SC17023 NA NA NA 1996

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction and workmanship conform to ASME Rules, Section VIII, Division 1 1995

6. Shell: SA-675-70 7/8" 0 8 1/4" 2' - 6 11/16"

7. Seams: SEAMLESS NA 100 NA NA NA NA NA

8. Heads: (a) Matl. NA (b) Matl. NA

9. MAWP 150 psi at max. temp. 300 °F

10. Nozzles, inspection and safety valve openings: Inspection openings per UG-46(a). **W/ SA403WP-316L ELL & SB-619-C-276 ELL & END PIPE

11. Supports: Skirt NA Lugs NA Legs 2 Other NA Attached WLD END FRAME

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: NA

*O.A. LENGTH: 3 7/16" DESIGN COMPLIES WITH UCS-66a., UHA-51a. & UNF-65

SUPERCHANGER TO CARRY: UNKNOWN HEATING SURFACE: 24.3 SQ.FT.

MODEL: UX-016-UJ-28 SEAL PLATE MAT'L.: SA-240-316L & SB619-C276 PLATES SB-575-C-276

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 8698 expires 12-31, 19 97.

Date 12-6-96 Co. name TEXAS DIVISION - TRANTER, INC. Signed Claude E. Boles

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by TEXAS DIVISION - TRANTER, INC. at WICHITA FALLS, TEXAS

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of TEXAS and employed by COMMERCIAL UNION INS. CO. OF MA. have

inspected the component described in this Manufacturer's Data Report on 12-6, 19 96, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12-6-96 Signed [Signature] Commissions TX 1083 NB5503AN

MASTER COPY

